



NOTES:

- 1.) FRAME, BLADES, AND COLLAR SHALL BE GALVANIZED STEEL CONSTRUCTION. COLLAR SHALL BE Min. 14 Ga thk.
- 2.) FOLLOW MANUFACTURER'S INSTRUCTIONS FOR THE INSTALLATION OF TYPE-"B" EXTERNAL CURTAIN FIRE DAMPERS and/or TYPE-"A" INTERNAL CURTAIN FIRE DAMPERS. STANDARD OF ACCEPTANCE = CONTROLLED AIR MANUFACTURING LIMITED, RUSKIN MANUFACTURING, or NAILOR INDUSTRIES INC.
- 3.) DO NOT SEAL AROUND RETAINING ANGLES w FIRESTOP CAULKS and/or PUTTYS. DO NOT FILL ANNULAR SPACE (EXPANSION VOID) w FIRESTOP MATERIAL.
- 4.) HORIZONTAL INSTALLATION SIMILAR, c/w STAINLESS STEEL CLOSURE SPRING.
- 5.) SUBMIT SHOP DRAWINGS TO THE ENGINEER FOR REVIEW PRIOR TO INSTALLATION.