

DESIGN ANALYSIS
SCALE 1:50MTS

- CONTINUOUS LOAD (GENERAL LIGHTING LOAD)
 LIGHTING LOAD = $(28M^2/FLOOR) \times (24VA/M^2) = 672 VA$
 LAUNDRY : 1 x 1500VA = 1,500 VA
 WATER HEATER : 1 x 3200 VA = 3,200 VA
 OUTLET 6 x 180VA = 1,080 VA
 SUB TOTAL = 6,452 VA
 APPLICATION OF OF DEMAND FACTOR BASE ON (TABLE 2.20.3.3)
 3,000VA @ 100% = 3,000 VA
 0.35 X (6,452-3,000) = 1208.2 VA
 OTHER LOADS
 RANGE: 4500 VA x 80% (TABLE 2.20.3.16) = 3,600 VA
 AIR-CONDITIONING LOAD: @ 100% D.F
 0.75 HP (6.9A x 230V) = 1,587 VA
 1.5 HP (10A x 230V) = 2,300 VA
NET LOAD TOTAL = 11,821.2 VA

- SERVICE FEEDER CONDUCTORS FOR EACH DWELLING UNIT (TABLE 3.10.2.6(B)(16))
 IF = $(11,821.2)/(230) + 0.25 \times (10)$
IF = 53.9 A
USE 2-8.0mm² THHN WIRE
2-5.5mm² TW GROUND WIRE
1-21mmØ IMC CONDUIT
- SERVICE FEEDER CIRCUIT BREAKER FOR EACH DWELLING UNIT
 ICB = $(11,821.2/230) + 1.5 \times (10)$
ICB = 66.4 A
USE 2P, MCB 70AT/100AF, 18 KAIC, 240V RMS


- VOLTAGE DROP CALCULATION:
 $V_d = (I) \times \sqrt{[(R'')^2 + (X'')^2] \times (L)} / (305m)$

NOTE : SINCE THE POWER SOURCE FROM SERVICE POLE TO SERVICE ENTRANCE WITH A DISTANCE OF LESS THAN 10 METERS, VOLTAGE DROP SHOULD NOT MORE THAN 5%
 D - LENGTH FROM THE MAIN SOURCE IS LESS THAN (10meter)
 A - CROSS SECTION AREA OF WIRE IN (8.0 mm² THHN)
 R'' - RESISTIVITY OF COPPER WIRE (0.78 ohm/305meter)
 X'' - REACTANCE OF COPPER WIRE (0.065 ohm/305meter)
 I - LOAD CURRENT IS (53.9 AMP)

$V_d \% = (53.9AMP) \times \sqrt{[(0.065)^2 + (0.78)^2] \times (10m)} / (305m)$
 $V_d \% = 1.383 \text{ volts}$
 $V_d \% = 1.383/230 \times 100\%$
Vd % = 0.60%, ACCEPTABLE VALUE, LESS THAN 5%

- SHORT CIRCUIT ANALYSIS

KVA CAP. OF TRANSFORMER = $[(53.9)(230V)] / 1000$
 = 12.397KVA
 REQUIRED SIZE OF TRANSFORMER MUST BE 15KVA
 Z = 1.2%




Step 1: If.I. = $15KVA / [(230)] = 65.22 A$
 Step 2: Mult. = $100/1.2 = 83.3$
 Step 3: Is.c. = $65.22 \times 83.3 = 5,432.83 A$

Step 4: "f" factor = $\frac{2 \times L \times |L-L|}{C \times n \times |EL-L|}$
 at length of 10mtrs or 32.81ft
 $f = \frac{2 \times 32.81 \times 5,432.83}{10,755 \times 1 \times 230V} = 0.1441$


Step 5: M = $\frac{1}{1 + 0.1441} = 0.8740$

Step 6: Is.c. sym RMS = $5,432.83 \times 0.8740 = 4,748.56 AMP$


THEREFORE, USE 10 KAIC MINIMUM INTERRUPTING CAPACITY OF MAIN CIRCUIT T BREAKER FOR SERVICE ENTRANCE AND USE 10 KAIC FOR BRANCH CIRCUIT.



SPECIFIED HEIGHT
SCALE 1:100MTS



LINE DIAGRAM
SCALE 1:50MTS



LEFT SIDE ELEVATION

SERVICE LAYOUT
SCALE 1:100MTS

DESIGNER:		PEE:		PROJECT TITLE:		APPROVED BY:		REVISIONS		SHEET CONTENTS:		SHEET NO.	
				PROPOSED 1 STOREY RESIDENTIAL W/ LOFT (TYPE A MODEL HOUSE)				DRAWN BY:		DESIGN ANALYSIS/ RISER DIAGRAM/ SERVICE LAYOUT/ SPECIFIED HEIGHT/ LINE DIAGRAM/ PERSPECTIVE VIEW			
PRC:		VALID:		LOCATION :		OWNER:		DATE:					
PTR:		DATE:						REVISION:					
								REV. DATE:					